

Thermocouple Splitter v3 BTCS726

DESCRIPTION

The thermocouple splitter BTCS726 takes one thermocouple input and provides two fully isolated outputs. Both outputs can retransmit the thermocouple or one can produce a linearised process signal (4-20mA) for remote data logging and supervision. Final calibration can be trimmed by using the front accessible SPAN (S) and ZERO (Z) potentiometers. The optional alarm point is also set by potentiometer utilising the adjacent test socket. The voltage at the test socket (referenced to terminal 13) gives a 0-5V trip set range representing 0-100% input. The wide swing DC/DC converter allows for two power supply ranges: 10-60Vdc (16-42Vac), 80-280Vac (80-300Vdc). Isolation is 2kVr.m.s. between all 5 ports.



General Specifications

Mounting: 35mm DIN-Rail. Termination Plug-in screw terminals.

Weight: 0.300 kg.

Protection class: IP40 (IP65 Enclosure optional.) 60W x 70H x 110D (mm). Size:

Housing material: ABS, aluminium.

0.2% of span for > 100°C span. Accuracy:

Linearity: 0.15% of span. Repeatability: 0.1% of span. 0...+60°C. Operating ambient: Storage temp. range: -20...+70°C. Temperature effect: 0.02% per °C. Cold junction

compensation error: 0.02% per °C

Output drive: 0 to 22mA (20V drive).

0 to 20V (100 k Ω min)

500ms standard (5ms link). Response time:

Zero/Span adjust: Typically ±20% Contact rating: 10A/250Vac resistive. Trip repeatability: <0.5% of range.

Trip response time: <100ms.

Switching hysteresis: 1 to 25% of range (default 1%).

Power requirements: 4VA 6-way Isolation: 2kV r.m.s.

Electromagnetic

CE and AS/NZS compatibility:

BTCS726-X X X X X Ordering code:

Supply:

1 = 80-300 Vdc / 80 - 280 Vac. 2 = 10-60 Vdc / 16 - 42 Vac

Specify - type (B E J K N R S T?)

calibration (20 - 300°C ?).

1 = Thermocouple

2 = Thermocouple with up scale burnout.

3 = Thermocouple with down scale burnout

Output: -

1 = CH1 Thermocouple. CH2 Thermocouple.

*) 2 = CH1 Link selectable (default 4-20mA). CH2 Thermocouple.

*) 3 = CH1 Process signal specify range. CH2 Thermocouple.

Alarm:

0 = Not fitted.

*) 1 = Change over 1% hysteresis.


Option:-

0 = none.


*) 2 = Customised response time.

*) = Price Extra..

Block Diagram



Connection



Changing link selectable output


This procedure only applies when ordering output option 2.


mV (use compensation cable)

- Disconnect power to unit. 1)
- Unscrew right-side cover and withdraw PCB assembly. 2)
- 3) Set the coding plugs SW1 as required.
- Reassemble unit and connect power.
- Adjust "span" and "zero" pots to recalibrate.
- Change the label information to the new input/output values

CH1 Output Selection C204 PCB

Output	1	2	3	4	5
4-20mA	Χ		Χ		
0-20mA		Х			
0-5V		Χ			Χ
1-5V	X		Χ		Χ
0-10V		Χ		Х	





Process outputs are linearised

In the interest of development and improvement, BASI reserve the right to amend, without notice, details contained in this publication. BASI will accept no legal liability for any errors, omissions or amendments