



# RESISTANCE TRANSMITTER (v5) BRT243


## DESCRIPTION

The BRT243 applies a constant current to a resistance device. On change of resistance value the voltage drop across the resistance device will change and becomes the input signal. The BRT243 is ideal for in field enclosures or as a space saver in larger control cabinets. Standard output is 4 - 20mA with a minimum supply voltage of 6.3V. This enables the BRT243 to be used in 12V battery supply systems or in automotive applications. Other factory set output configurations are 10 - 50mA loop powered and 0 - 10mA, 0 - 20mA or voltage output in 3-wire connection up to 40Vdc. Double surge protection is standard with all Series 200 loop powered transmitters to prevent failure due to spikes induced by DC switched inductive loads. The input is isolated from the output as standard. Base calibration is set with 2 metal film resistors on the input card. This input card consists basically of a precision current source adjustable by a 15-turn potentiometer located on the input card. A buffer amplifier is used to condition the input voltage to the uniform card output of 0 - 1V. Final calibration is trimmed using the front accessible zero and span 15-turn trim adjustments. A front mounted L.E.D. and a test socket verify module function and assist in calibration checks without disconnection of output wires.



## GENERAL SPECIFICATIONS

Size:	23.5W x 71.5H x 109D (mm).
Mounting:	Clip for 35mm DIN-Rail.
Housing material:	ABS.
Connection:	Screw terminals.
Weight:	106 g.
Accuracy error:	<0.2%.
Linearity error:	<0.2%.
Protection class:	IP40 (IP65 refer to BRT543).
Ambient operating temp. range:	-20...+70°C.
Temperature drift error:	<0.2% within operating range (not taking account of input lead resistance).
Supply voltage:	6.3 - 40V continuous (50V 30 seconds).
Load for 4 - 20mA output:	$RL_{max} = \frac{SupplyVoltage - 6.3V}{0.02A} [\Omega]$ .
Load change effect:	0.1% up to RL max.
Response time:	0.5 sec to T <sub>90</sub> .
Optional internal offset adjustment:	±50%.
(Zero suppression/elevation)	
Front Zero adjust:	+20% / -10%.
Front Span adjust:	±25%.
Input range:	50 Ω up to 10k Ω.
Excitation current:	0.6mA max.
Input/output isolation:	2kV.
Electromagnetic compatibility:	Complies with EN 50081-1, EN 50082-2



For input/output combinations refer to TYPE NO. DESIGNATION overleaf.



**BASI Instrument AB**  
P.O. Box 53

Tel: +46 40-880 09  
SE-275 06 VOLL SJÖ.....SWEDEN

Fax: +46 40-92 98 77  
E-mail: info@basi.se

**BASI RESISTANCE TRANSMITTER**

**BRT243**

No. **DS 43:10-E** Issue: 6 8/08/11

### TYPE NO. DESIGNATION

#### Output:

1 = 4 - 20mA.	} 2-wire	*) 6 = 0 - 1V.	} 3 - wire
2 = 10 - 50mA.			
*) 3 = 0 - 1mA.	} 3 - wire	*) 7 = 0 - 5V min. supply 10.5Vdc.	} 0V Ref.
*) 4 = 0 - 10mA.		*) 8 = 0 - 10V min. supply 15.5Vdc.	
*) 5 = 0 - 20mA.		*) 9 = Other (Specify).	

#### Input Span:

1 = 0 - 200 $\Omega$ (100 - 300 #).	6 = 0 - 3.5k $\Omega$ (2k8 - 4k3 #).
2 = 0 - 500 $\Omega$ (250 - 750 #).	7 = 0 - 5k $\Omega$ (4k2 - 5k7 #).
3 = 0 - 1k $\Omega$ (500 - 1k5 #).	8 = 0 - 10k $\Omega$ (5k - 12k9 #).
4 = 0 - 1.5k $\Omega$ (1k - 2k5 #).	*) 9 = Other (Specify).
5 = 0 - 2.5k $\Omega$ (1k8 - 3k4 #).	

#### Action:

1 = Direct.	*) 2 = Reverse.
-------------	-----------------

#### Options:

- 0 = None.
- \*) 1 = Output ramp.
- \*) 2 = Offset inputs up to 100% of span.
- \*) 9 = Other (Specify).

# = Indicates span range that can be achieved for the specified input using an internal adjustment.


\*) = Price Extra.

Refer to CP24301 for the internal adjustment procedure if required.

### Front Control Explanation


1. Test socket - output signal access with reference to terminal (1) loop integrity is maintained when digital multimeter Rin <30  $\Omega$  is used.
2. Loop indicator - dim at 4mA, bright at 20mA.
3. SPAN (full scale) adjust 15 turn.
4. ZERO (start scale) adjust 15 turn.

### Connection Example



NOTE: RL is input load of PLC, VSD, or other process instrument.

### Connection Diagrams



In the interest of development and improvement, BASI reserve the right to amend, without notice, details contained in this publication. BASI will accept no legal liability for any errors, omissions or amendments.